



कार्यपालक अभियंता का कार्यालय कुर्नूल
केन्द्रीय लोक निर्माण विभाग
भारतीय सूचना प्रौद्योगिकी अभिकल्पना एवं विनिर्माण
संस्थान कैपस,
जगन्नाथ गट्टू, जीपुल्ला रेड्डी पोस्ट.,
कुर्नूल - 518007
फ़ोन/Ph. No: 9490667017



भारत सरकार

Government of India



Office of the Executive Engineer
Kurnool

Central Public Works Department
IIIT-DM Kurnool Campus,
Jagannatha Gattu, G.Pulla Reddy Post, Kurnool-
518007

ई-मेल/e-mail: krnee-kcd@cpwd.gov.in

पत्रांक से: 12(40)/ का. अ/ कुर्नूल /2023/ 108-109 (हिं)

दिनांक: 11 /07/2023

सेवा में,

The principal,
Kendriya Vidyalaya Kurnool,
Kurnool Dist.

विषय:- Issue of Structural Stability Certificate in respect of school building and compound wall -Reg

संदर्भ: Your office: Lr. CPWD/KV/Kurnool/2023-24; dated: 12.06.2023.

महोदय,

With reference to the above, it is certified that School building of the Kendriya Vidyalaya, Kurnool, inspected by the Assistant Engineer, Kurnool on 11.07.2023 is found to be structurally safe for the period 2023-24.

Note: it is observed that regular maintainance of the building is to be immediately takenup, rectification of uneven settled ground floor flooring, raise compound wall by 0.75 m height along with repairs.

भवदीय,

जी.ए.एस.एस.सिवाय
कार्यपालक अभियंता,
के.लो.नि.वि, कुर्नूल

प्रतिलिपि:

1. सहायक अभियंता-II, के.लो.नि.वि, कुर्नूल, सूचनार्थ एवं आवश्यक कार्यवाही हेतु.

-/ कार्यपालक अभियंता /-

